

CERTIFICATE OF COMPLIANCE

Certificate Number S25094
Report Reference S25094-20220525
Date 2022-May-27

Issued to: NITTAN CO LTD
54-5, 1-CHOME SASAZUKA
SHIBUYA-KU TOKYO 151-8535 JP

**This is to certify that
representative samples of**

SMOKE DETECTORS FOR FIRE ALARM SYSTEMS;
HEAT-AUTOMATIC FIRE DETECTORS

Single Criteria, Photoelectric, Analog Addressable,
Smoke/Heat Detector with complementary Heat Detector,
Fixed Temperature 135°F (57.2°C) and Rate Of Rise 15°F
(8.3°C)/ minute, Model EVA-PYH3.
Single Criteria, Photoelectric, Analog Addressable, Smoke
Detector, Model EVA-PY3.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 268, Smoke Detectors for Fire Alarm Systems.


ANSI/UL 521, Heat Detectors for Fire Protective Signaling
Systems.

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

