

CERTIFICATE OF COMPLIANCE

Certificate Number 20150112-S25165
Report Reference S25165-20150108
Issue Date 2015-JANUARY-12

Issued to: NITTAN CO LTD
54-5, 1-CHOME SASAZUKA
SHIBUYA-KU
TOKYO 151-8535 JAPAN

**This is to certify that
representative samples of**

HEAT-AUTOMATIC FIRE DETECTORS
Heat Detector head, intelligent (addressable), Model EVA-
H2 combination 135 °F (57.2 °C) fixed temperature and 15
°F/min (8.3 °C/min) rate of rise.

Heat Detector head, intelligent (addressable), Model EVA-
H2-H 181.4 °F (83.0 °C) fixed temperature.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 521, Heat Detectors for Fire Protective Signaling
Systems

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

